



Pilkington **Pyrostop**™ in Multi-pane Timber Screen

60 minutes integrity & 60 minutes insulation

A clear, fully insulating fire resisting glass providing the highest levels of fire and impact protection.

ASSESSMENT REFERENCE: C82780

TEST STATION: Warrington Fire Research Centre


TEST DATE: 13th October 1997

TEST SPONSOR: Pilkington United Kingdom Limited

TEST STANDARD: BS 476: Part 22: 1987 GENERAL DESCRIPTION OF THE ASSEMBLY

- 21mm Pilkington Pyrostop or 27mm Pilkington Pyrostop
- Single glazing, or double glazed with non-fire rated glass
- Multi-pane hardwood screen
- Hardwood glazing beads
- Intumescent material incorporated into the construction


Elevation



Key to figures

- 21mm Pilkington Pyrostop or 27mm Pilkington Pyrostop
- Double glazing unit
 (Pilkington Pyrostop/8mm cavity/
 6mm secondary pane)
- 92 × 40mm hardwood frame (Brazilian mahogany, minimum density 570 kg/m³). Dimension varied to suit thickness of single glazing or double glazed unit and dimension of glazing beads
- 4 30 × 25mm hardwood glazing beads
- 5 5mm thick hardwood setting block
- 50mm long No. 8 or No. 10 steel screws at nominal 200mm centres. Screw fixings splayed so that screws extend at least 40mm into framing members.
- 7 20 × 3mm proprietary glazing medium, either: CARBORUNDUM RESISTANT MATERIALS LTD, Fibrefrax ceramic tape DUFAYLITE DEVELOPMENTS LTD, Interdens intumescent seal MANN McGOWAN FABRICATIONS LTD.
- Pyroglaze 500P

 Mastic pointing, either:
- Intumescent mastic, or
 ADSHEAD RATCLIFFE & Co. LTD.
 Arbo 1081 silicone mastic
 GE SILICONES GE1200 silicone mastic



Scope

The results of this assessment relate only to the behaviour of the specimen of the element of construction under the particular conditions of the test. They are not intended to be the sole criteria for assessing the potential fire performance of the element in use nor do they reflect the actual behaviour in fires.

21 and 27mm Pilkington **Pyrostop** glasses are classified as Class A safety glasses according to the impact performance requirements of BS 6206: 1981, and have been tested extensively in accordance with the fire test requirements of BS 476: Part 22: 1987.

This publication gives a general description of the product and materials. It is the responsibility of the user to ensure that their use is appropriate for any particular application and that such application complies with all relevant local and national legislation, standards, codes of practice and other requirements.

Pilkington United Kingdom Limited hereby disclaim all liability howsoever arising from any error in or omission from this publication and for all consequences of relying on it.

Pilkington **Pyrostop™** is a trade mark of the Pilkington Group.

For technical advice please contact the numbers below.



Pilkington United Kingdom Limited
Prescot Road St Helens England WA10 3TT
Telephone 01744 69 2000 Fax 01744 613049